



SCALE: - 2/1

MATERIAL:- BRASS TO B.S.SPEC: 249 (LATEST ISSUE)

FINISH:- ELECTRO-TIN TO SPEC: D.T.D. 924 (LATEST ISSUE)

NOTES:- THREADS TO BE IN ACCORDANCE WITH B.S.SPEC: 84, (LATEST ISSUE), MEDIUM FIT.

ALL DIAMETRICAL SURFACES TO BE CONCENTRIC WITHIN .004" (T.C.R.)

ALL SHARP EDGES AND BURRS TO BE REMOVED.

SM 591 SM 677 SM 716

TITLE:- L.T. CABLE UNION NUT

ISSUE	11	12	13				
ALT.N <sup>o</sup>	AS/AGS 876	AS/AGS 959	AS/AGS 966				

MINISTRY OF SUPPLY  
APPLICATIONS FOR A.G.S. SHEETS TO  
ATP 4A THAMES HOUSE, MILLBANK, SW1

R.A.E. APPROVAL		A.D. S.A.E. APPROVAL	
SIGNATURE	DATE	SIGNATURE	DATE
<i>H. Smith</i>	8.1.52	<i>G.T. Lambton</i>	27/6/52

GENERAL INQUIRIES TO:-  
A.D.S.A.E. THAMES HOUSE, MILLBANK, SW1

SHEET NO	1	A.G.S. No 1519
NO OF SHEETS	1	

ORIGINAL APPROVAL DATE 27.3.25